

# NELSON ANALYTICAL LAB

120 York Street, Kennebunk, ME 04043  
 www.nelsonanalytical.com  
 (207)467-3478 phone

## REPORT OF ANALYSIS

Laboratory ID: 219040239

NH ELAP Accreditation #NH2018  
 Maine State Certification # ME0015  
 Maine Radon Certification # ME17500

Client Name: Middleton School District Attn: \_\_\_\_\_  
 Date Reported : 04/09/2019

**Client Sample ID: Middleton Elementary** **Date Collected: 04/05/2019 06:52 AM**  
**Laboratory ID: 219040239.01** **Collected By : Client**  
**Sample Location: Rm 114** **Date Received : 04/05/2019 01:14 PM**  
**Sample Matrix : Drinking Water** **Temperature Rec'd°C: 17.6#**

Parameter	Result	Units	Method	Rpt Limit	Q	Date/Time Analyzed	Analyst
Lead	<0.001	mg/L	EPA 200.8	0.001		04/08/2019 19:18	JH

**Client Sample ID: Middleton Elementary** **Date Collected: 04/05/2019 06:53 AM**  
**Laboratory ID: 219040239.02** **Collected By : Client**  
**Sample Location: Rm 115** **Date Received : 04/05/2019 01:14 PM**  
**Sample Matrix : Drinking Water** **Temperature Rec'd°C: 17.6#**

Parameter	Result	Units	Method	Rpt Limit	Q	Date/Time Analyzed	Analyst
Lead	<0.001	mg/L	EPA 200.8	0.001		04/08/2019 19:18	JH

Respectfully Submitted



**Lorri Maling, Laboratory Director**



Notes: mg/l=ppm; ug/l=ppb; "<" denotes "less than". This report of analysis may not be modified in any way, or reproduced except in full, without written approval from Nelson Analytical, LLC. Results reported above relate only to samples as submitted, unless specifically noted otherwise. Nelson Analytical, LLC is currently accredited by the New Hampshire Environmental Lab Accreditation Program, the Vermont Laboratory Accreditation Program, and the Maine Laboratory Certification Program. For a list of current accredited tests, please visit the websites listed below. Sampling performed by the lab is according to the lab document "Water Sampling Instructions". EPA standards list pH & Chlorine as field parameters and they should be tested immediately at sample collection. Samples tested for pH are analyzed beyond the hold time for the analysis. Samples will be analyzed as quickly as laboratory operations allow. Metals samples may be analyzed the same day they are received. # - Sample(s) received at laboratory do not meet method specified temperature criteria. Subcontracting Information: SUB1=NH1005(EPA-NH01005); SUB3=NH1004(EPA-NH00035)SUB4=NH2073, SUB5=NH2530 SUB6=NH2124 ME IN00035 SUB7-NH 1007; SUB 8=ME00002  
[http://des.nh.gov/organization/divisions/water/dwgb/nhelap/http://healthvermont.gov/enviro/ph\\_lab/PublicHealthLaboratory.aspxhttp://www.maine.gov/dhhs/mecdc/environmental-health/dwp/professionals/labCert.shtml](http://des.nh.gov/organization/divisions/water/dwgb/nhelap/http://healthvermont.gov/enviro/ph_lab/PublicHealthLaboratory.aspxhttp://www.maine.gov/dhhs/mecdc/environmental-health/dwp/professionals/labCert.shtml)

Date: 04/09/2019 13:33